

CERTIFICATE



No. 0H221223.RESSQ53

Test Report / Technical Construction File no. XMT0202200698S/LVD, XMT0202200699S/EMC

Certificate's Holder: REVALCO ELECTRIC SPAIN, S.L.

Certification
ECM Mark



Product: Miniature Circuit Breaker
(with EN Overvoltage Delay Device & SPD Protection)

Model(s): (see the following annex)

Verification to: Standard:
IEC 60898-1:2019+C1:2020, IEC 61643-11:2011,
EN IEC 63052:2021, EN 50550:2011+A1:2014,
EN IEC 61000-6-1:2019, EN IEC 61000-6-3:2021,
EN IEC 61000-3-2:2019+A1:2021,
EN 61000-3-3:2013+A2:2021

related to CE Directive(s):
2014/35/EU (Low Voltage)
2014/30/EU (Electromagnetic Compatibility)

This document has been issued in accordance with the European Commission's note of 14 September 2022 ref. Ares (2022) 6342894 concerning voluntary certifications with a non-notified procedure.

The manufacturer has voluntarily decided to submit its documents concerning the above-mentioned product for verification. Ente Certificazione Machine confirms that the documentation made available and immediately returned to it, as containing sensitive data, meets the essential requirements of the above-mentioned directives. The verification activity carried out exclusively concerned the technical documentation and no verification was carried out on the product. This document cannot replace the EC Declaration of Conformity. The above conformity mark can be affixed to the technical documentation in accordance with the ECM regulation on its issue and use, published on the website www.entecerma.it

Issuance date: 23 December 2022

Expiry date: 22 December 2027

For online check:



Approver
Ente Certificazione Machine
Legal Representative
Luca Bedonni



Ente Certificazione Macchine Srl

Via Ca' Bella, 243 – Loc. Castello di Serravalle – 40053 Valsamoggia (BO) - ITALY
☎ +39 051 6705141 📠 +39 051 6705156 ✉ info@entecerma.it 🌐 www.entecerma.it

Annex I



No. 0H221223.RESSQ53

Test Report / Technical Construction File no. XMT0202200698S/LVD, XMT0202200699S/EMC

Model(s):

IGA10PT2P**EN Series, IGA10PT4P**EN Series, RV30 OS3 Series

Ue=240V~(1P+N),415V~(3P+N)

In=6A,10A,16A,20A,25A,32A,40A,50A,63A

Rated Frequency:50/60HZ

SPD: T2 1P+N (Uc=400Vac,I_{max}=15kA,I_n=5kA,U_p=1.5kV) 3P+N
(Uc=420Vac I_{max}=40kA,I_n=20kA,U_p=2.0kV)

