

La empresa: **REVALCO ELECTRIC SPAIN, S.L.**
C/Plomo, 10 Nave C
28770 Colmenar Viejo (Madrid)

Declara que los productos: **INTERRUPTORES AUTOMÁTICOS MAGNETOTÉRMICOS 10 KA**
Declares that the product/s: Automatic magnetic circuit breaker 10 KA (MCB)

Referencias: **10 KA (RV30H...; RV303H...;)**
Reference: 10KA (RV30H...; RV303H...;)

Corriente asignada: **De 1 A hasta 125 A**
Rated current: From 1 A to 125 A

Tensión de empleo: **240/415 Vca**
Rated Voltage: 240/415Vac

Curvas: **B / C / D**
Curves: B / C / D

Instalados de acuerdo con las normas de instalación, instrucciones profesionales, debidamente mantenidos y utilizado en las aplicaciones para las que está previsto

Installed in accordance to the installation standards, manufacturer's instruction and professional rules, duly maintained and used for the applications as intended

Cumple con los requisitos de la Directiva del Parlamento Europeo y del Consejo: 2014/35/UE, XMT0202200692S/LVD (Directiva de Baja Tensión)
2014/30/UE, XMT0202200693S/EMC (Directiva de Compatibilidad Electromagnética)
2011/65/UE (ROHS) Directiva Rohs
Complies with the Directive requirements Of the European Parliament and of the Council:

Mediante la conformidad con las siguientes Normas: IEC 60898-1:2019+C1:2020, IEC 60947-2:2019,
EN IEC 61000-6-1:2019, EN IEC 61000-6-3:2021,
By conformity with the following standards: EN IEC 61000-3-2:2019+A1:2021,
EN 61000-3-3:2013+A2:2021

Información Adicional: Estos productos están previstos para ser instalados y mantenidos por un profesional
Additional information: This product is intended to be installed and maintained by skilled person

Marcado CE: 2022
CE marking:

Fecha de Expedición: 23 de Diciembre del 2022
Date of issue:

Firmado por: Ángel Pulido Ariño (Presidente)
Signed for: President

RVDCCEMCH23122022

