# CERTIFICATE

#### No. 0H221223.RESSQ52



Test Report / Technical Construction File no. XMT0202200692S/LVD, XMT0202200693S/EMC

### Certificate's Holder:

REVALCO ELECTRIC SPAIN, S.L.

Certification ECM Mark



Product: Model(s): Miniature Circuit Breaker (see the following annex)

Verification to:

Standard: IEC 60898-1:2019+C1:2020, IEC 60947-2:2019, EN IEC 61000-6-1:2019, EN IEC 61000-6-3:2021, EN IEC 61000-3-2:2019+A1:2021, EN 61000-3-3:2013+A2:2021

related to CE Directive(s): 2014/35/EU (Low Voltage) 2014/30/EU (Electromagnetic Compatibility)

This document has been issued in accordance with the European Commission's note of 14 September 2022 ref. Ares (2022) 6342894 concerning voluntary certifications with a non-notified procedure.

The manufacturer has voluntarily decided to submit its documents concerning the above-mentioned product for verification. Ente Certificazione Macchine confirms that the documentation made available and immediately returned to it, as containing sensitive data, meets the essential requirements of the above-mentioned directives. The verification activity carried out exclusively concerned the technical documentation and no verification was carried out on the product. This document cannot replace the EC Declaration of Conformity. The above conformity mark can be affixed to the technical documentation in accordance with the ECM regulation on its issue and use, published on the website www.entecerma.it

#### Issuance date: 23 December 2022

#### Expiry date: 22 December 2027

For online check:





## Annex I

No. 0H221223.RESSQ52



Test Report / Technical Construction File no. XMT0202200692S/LVD, XMT0202200693S/EMC

### Model(s):

RV30H, RV303H High Model Series Ue=240/415V~(1P),240V~(1P+N),415V~(2P,3P,3P+N,4P) In=1, 2, 3, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63, 80A, 100A, 125A B-, C- and D-Type IEC 60898-1:Icn=10000A, Ics=7500A,Energy limiting class 3(Only for B,C type) IEC 60947-2:Icn=15000A, Ics=10000A,Energy limiting class 3(Only for B,C type)